


MCU Reset:

Valid for MCU1.0 --> from firmware 113

Valid for MCU2.0 --> from firmware 210

Setting MCU to default settings and clear datalogger without using the Modcom.

1. MCU Power off
2. Dip1,4 --> off; Dip2,3 --> on
3. MCU Power up



picture 1: MCU LEDs

4. MCU Power off
5. Dip1-4 back to the individual settings:

Intern Timer battery on:	Dip1 --> on
Intern Timer battery off:	Dip1 --> off
12V system:	Dip2 --> off, Dip3 --> off
24V system:	Dip2 --> off, Dip3 --> on
48V system:	Dip2 --> on, Dip3 --> off
Gel battery:	Dip4 --> on
Liquid battery:	Dip4 --> off
6. Power up

MCU is now reseted. All settings now default settings. All datalogger values are cleared.